

## Attestation of Conformity No. 231208-01

This attestation of conformity corresponds to the standard  
EN ISO/IEC 17050-1  
„Conformity assessment – Supplier’s declaration of conformity- Part 1: General requirements”.

We, the manufacturer:                    EPHYMESS GmbH  
Berta-Cramer-Ring 1  
65205 Wiesbaden  
Germany

declare under sole responsibility that the product (component)

model:    Temperature sensor  
Type: PR-SPA-EX-WKF  
II 2G Ex eb IIC Gb  
II 2D Ex tb IIIC Db  
II 2G Ex ia IIC Gb  
II 2D Ex ia IIIC Db

to which this declaration relates is in conformity with the following standard(s) or other normative documents:

- EN IEC 60079-0:2018
- EN IEC 60079-7:2015 +A1:2018
- EN 60079-11:2012
- EN 60079-31:2014
- IBExU 23 UKEX 0011 U, Issue 00

approved body which carried out the conformity assessment procedure:

IBExU UK Ltd., Bristol Road South, Regus Park House,  
Birmingham, B45 9AH, United Kingdom

in accordance with the provisions of the directive(s):

- SI 2016 No. 1107 as amended (UKEX equipment directive)
- Directive 2011/65/EU ((RoHS II+III))

Wiesbaden, 11.12.2023  
city / date

*M. Litzinger*  
M. Litzinger, EX Authority

*G. Herdt*  
G. Herdt, EX Authority

Registration court  
District court Wiesbaden  
EPHY-Mess Gesellschaft für Elektro  
Physikalische  
Meßgeräte mbH  
HRB-Nr.: 22 729  
VAT Reg. No. DE113842153  
founded:1955  
CEO  
Dipl.-Kfm. Andreas Becker  
Tobias Jennißen  
Patricia Mohr

Registered office  
Berta-Cramer-Ring 1  
65205 Wiesbaden, Germany  
  
Phone: +49 61 22 92 28 -0  
Fax: +49 61 22 92 28 -99  
  
E-Mail: info@ephy-mess.de

Quality assurance system  
Certified according to  
  
DIN ISO 9001    DIN ISO 14001

