



Attestation of Conformity
No. 210126-01

This attestation of conformity corresponds to the standard
DIN EN ISO/IEC 17050-1
„Conformity assessment – Supplier’s declaration of conformity- Part 1: General requirements”.

We, the manufacturer: EPHY-MESS GmbH
 Berta-Cramer-Ring 1
 65205 Wiesbaden
 Germany

declare under sole responsibility that the product (component)

model: Temperature sensor
 Type: PR-SPA-EX-WKF
 II 2G Ex eb IIC Gb
 II 2D Ex tb IIIC Db
 II 2G Ex ia IIC Gb
 II 2D Ex ia IIIC Db

to which this declaration relates is in conformity with the following standard(s) or other normative documents:

- EN 60079-0:2018
- EN 60079-7:2015 +A1:2018
- EN 60079-11:2012
- EN 60079-31:2014
- IExU 14 ATEX 1281 U, 2. Issue


in accordance with the provisions of the directive(s):

- Directive 2014/34/EU (ATEX equipment directive)
- Directive 2011/65/EU (RoHS II)

www.ephy-mess.de

Wiesbaden, 20.01.2021
city / date

Bernd Horneffer
Bernd Horneffer, EX-Authority



Commercial registries
 Registration court Wiesbaden
 HRB-Nr.: 22 729
 VAT REG No. DE113842153
 founded:1955
 General manager
 Dipl.-Kfm. Andreas Becker

Registered office
 Berta-Cramer-Ring 1
 65205 Wiesbaden, Germany
 Phone: +49 61 22 92 28 -0
 Fax: +49 61 22 92 28 -99
 E-Mail: info@ephy-mess.de

Quality assurance system
 Certified according to
 DIN ISO 9001
 DIN ISO 14001

