



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Ex COMPONENT CERTIFICATE

Certificate No.: **IECEX IBE 20.0001U** Page 1 of 3 [Certificate history:](#)

Status: **Current** Issue No: 0

Date of Issue: 2020-03-06

Applicant: **EPHY MESS GmbH**
Berta-Cramer-Ring 1
65205 Wiesbaden-Delkenheim
Germany

Ex Component: Electric Band Heater PR-HEI-EX-SSH

This component is NOT intended to be used alone and requires additional consideration when incorporated into other equipment or systems for use in explosive atmospheres (refer to IEC 60079-0).

Type of Protection: **Ex eb**

Marking: Ex eb IIC Gb

Approved for issue on behalf of the IECEx
Certification Body:

Alexander Henker

Position:

Deputy Head of department Certification Body

Signature:
(for printed version)

Date:
(for printed version)

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

IBExU Institut für Sicherheitstechnik GmbH
Fuchsmühlenweg 7
09599 Freiberg
Germany





IECEx Certificate of Conformity

Certificate No.: **IECEx IBE 20.0001U**

Page 2 of 3

Date of issue: 2020-03-06

Issue No: 0

Manufacturer: **EPHY MESS GmbH**
Berta-Cramer-Ring 1
65205 Wiesbaden-Delkenheim
Germany

Manufacturing
locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

[IEC 60079-0:2017](#) Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

[IEC 60079-7:2017](#) Explosive atmospheres - Part 7: Equipment protection by increased safety "e"
Edition:5.1

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

[DE/IBE/ExTR20.0003/00](#)

Quality Assessment Report:

[DE/IBE/QAR15.0001/02](#)



IECEx Certificate of Conformity

Certificate No.: **IECEx IBE 20.0001U**

Page 3 of 3

Date of issue: 2020-03-06

Issue No: 0

Ex Component(s) covered by this certificate is described below:

The heating element consists of a glass fibre carrier body, which is spirally wrapped around the heating conductor.

The electric band heater PR-HEI-EX-SSH is suited for fixed installation on the windings (usually winding heads) of electric motors / generators in order to protect them thermally against condensation water.

The Electric Band Heater PR-HEI-EX-SSH is not of a self-limiting design.

Electrical values

Operating voltage	115 V AC/ 230 V AC
Heat output	8 W ... 200 W (is determined depending on the variant)
Heat output per wire	≤ 25 W/m (determined according to the variant)
Rated service temperature range	-60 °C ... +180 °C - Sum of max. ambient temperature, self-heating and external heat
Max. permissible current	is determined according to the variant

Mechanical values

Min. bending radius of heating cable	≥ 10 mm (not valid for end pieces)
Tensile strength (wire / heating cord)	≤ 25 N

Dimensions

Heating cable	Height	min. 9.5 mm
	Width:	min. 2.5 mm
	Length:	depends on the capacity and according to customer requirements
Supply line	Design:	single strands, flat ribbon or hose line
	Construction/ insulation:	Cu-tinned - FEP
	Cross section:	≥ 1 mm ²

SCHEDULE OF LIMITATIONS:

The Electric Band Heater PR-HEI-EX-SSH has to be installed in a separate certified enclosure with a degree of protection of min. IP54 according to IEC 60079-0. The end caps of the heater must be under compound.

The rated service temperature range of -60 °C to +180 °C must be considered.

The electrical connection must comply with IEC 60079-7 when installed.